



## **STANDARD 28: SOFT WATER UNITS**

**JANUARY 1982**

**REVISED APRIL 1996, RESOLUTION M3-96-28**

**GENERAL REQUIREMENTS REVISED APRIL 2011, RESOLUTION 03-11-49**

**REVISED NOVEMBER 2019, RESOLUTION 03-19-132**

### **1.0 GENERAL REQUIREMENTS**

See Standard Section 1: General Requirements

### **2.0 INSTALLATIONS**

- 2.1** All installations require approval by the Permits and Inspection office prior to commencing the work.
- 2.2** Tanks may be located in a garage, water heater cabinet, or outside of unit as approved by the Permits and Inspection Office.
- 2.3** Exposed exterior installations must be enclosed in a 5/8" CDX cabinet, textured (to match exterior wall) or paneled and painted (inside and out) to match the color of the building. All exposed plumbing shall be painted color of surface to which attached.
- 2.4** Pipe runs shall be kept to a minimum.
- 2.5** Isolation valves for emergency shut-off will be required.
- 2.6** Soft water units shall be connected directly to the service line of the manor owner/owners' name that appears on the permit.
- 2.7** No regenerative-type softeners will be allowed as per all applicable laws.
- 2.8** Approval of landscape installation to conceal the soft water unit cabinets will be required.